



INTERNATIONAL
BRIDGE
TECHNOLOGIES,



5 February, 2013

Ms. Biljana Rajlic
Hatch Mott MacDonald
2800 Speakman Drive
Mississauga, Ontario L5K 2R7

RE: Independent check of the Malden Road Overpass (Bridge B04)

Dear Ms. Rajlic,

This letter confirms that International Bridge Technologies has completed an independent check of the **Malden Road Overpass (B04)**, for the Windsor Essex Parkway project.

We have completed our review and provided comments based on the plans submitted in the **Issued For Construction** drawings dated **1 February 2013**, and are satisfied that the structure will meet the requirements of the project agreement provided the following comments are addressed:

HMQ acceptance of single CSP detail for abutment piles behind RSS walls.

The design, methodologies and assumptions are consistent with Good Industry Practice.

We intend to issue a certificate for the structure, subject to review of the final (Issued For Construction) plan set.

Yours Sincerely,

International Bridge Technologies Canada
Zachary McGain
General Manager

International Bridge Technologies Canada, Inc.
1435 Rue St Alexandre, Suite 1210
Montréal Québec, H3A 2G4